

Zertifikat

Certificate



Zertifikat Nr. Certificate No.
R 50581553

Blatt Sheet
0001

Ihr Zeichen Client Reference
X.X.H.

Unser Zeichen Our Reference
01-WSW-50166049 008

Ausstellungsdatum Date of Issue
16.05.2023 (day/mo/yr)

Genehmigungsinhaber License Holder
Xiamen Suntrans New Energy
Technology Co.,Ltd.
Unit 1403A, 167 Tapudong
Road, Siming District, Xiamen
361008 Fujian
P.R. China

Fertigungsstätte Manufacturing Plant
040-0002120668

Prüfzeichen Test Mark



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111267666

Geprüft nach Tested acc. to
IEC 62930:2017

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Cable (Electric Cables for Photovoltaic Systems)

Type Designation : 62930 IEC 131 1X1,5...240mm² 12
HALOGEN FREE LOW SMOKE
Xiamen Suntrans New Energy
Technology Co.,Ltd.

Rated Voltage : DC 1,5kV

Max. Storage Temperature : +45°C

Min. Temperature for
Installation and Handling: -25°C

Max. Temperature
at Conductor : 120°C

12

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.



Zertifizierungsstelle

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

Kenny Shi